

HYDROGEOLOGIC DATABASE Chemical Analysis

Sample Results Color Code Legend

Click HERE to View Information for Well EVD

Sample Secondary Primary MCL



Well Key: EVD Site Type: Wellfield T

TRS: 32N/02E-22H

PWS Name: Bayshore Terrace Water System DOH PwsID: 04930 DOH Source #: 3

			Bicarbonate		Conductivity			Hardness						Turbidity		
Source	Date	Alk	As	Ca	Cl		Fe		K	Mg	Mn	Na	NO3	SO4		TDS
DOH	8/4/2016		0.0029		< 20	280	< 0.1	130			0.045	12	< 0.2	< 50	< 0.1	
DOH	8/30/2016		0.0035		< 20	420	< 0.1	130			0.036	13	< 0.2	< 50	< 0.1	
DOH	8/29/2017												< 0.2			
DOH	9/27/2018												< 0.5			
DOH	8/26/2019												< 0.5			
DOH	8/27/2020												< 0.5			

Select Summary	Avg As:	0.003	Avg Cl:	10.0	Avg Hardness:	130	Avg NO3:	0.17
Statistics Statistics	Median As:	0.0032	Median CI:	10.0	Median Hardness:	130	Median NO3:	0.175
Statistics	Max As:	0.0035	Max Cl:	10.0	Max Hardness:	130	Max NO3:	0.25

Bacteria Samples (distribution): 475 sample(s)

Disclaimer: Data presented has been collected from a variety of sources. Island County makes no guarantee as to the validity or accuracy of this data.

Please report any errors to the Island County Hydrogeologist.

Generated by the Island County Hydrogeologic Database

6 records printed on 9/16/2020

Note: Items with blue frames and blue text are clickable hyperlinks to additional information / resources.

Parameter labels with a red fill color are exhibiting an increasing trend, and those with a green fill color are exhibiting a decreasing trend.

WellKey: EVD Page 1 of 1